



REV6

Operation / Maintenance Manual



This manual contains information necessary for the safe and proper use of the Rev6. Included are specifications for the standard configurations of the pump system and instructions regarding its use, installation, operation, adjustment, inspection, and maintenance. For special configurations of the pump system, refer to accompanying information. Please familiarize yourself with the contents of the manual to ensure the safe and effective use of this product. After reading this manual, please store the manual where the personnel responsible for operating the pump system can readily refer to it at any time.


Table of Contents

1	Safety Precautions	4
2	Specifications	5
2.1	Specification of Components	5
2.2	Standard System Configurations	9
2.2.1	Pump Only Configuration	9
2.2.2	Stand-Alone System Configuration	9
2.2.3	Extended System Configuration	10
2.3	General Environmental Conditions	12
2.4	Pump Performance Curves	12
2.4.1	Pressure-Flow Curves	12
2.4.2	NPSHr Curves	13
2.4.3	Maximum Static Pressure vs. Fluid Temperature	13
2.5	Basic Dimensions of Main Components	14
2.6	Air Cooling Module	17
2.7	Cable Minimum Bend Radius	18
3	Engineering Information	19
3.1	Sealing and Material Concept	19
3.2	Power Consumption	20
3.3	Temperature Monitoring	21
3.4	Thermal Management	22
3.4.1	Motor Temperature	22
3.4.2	Controller Temperature	24
3.5	Hydraulic Circuit Design	25
4	Installation	26
4.1	Electrical Installation of Controller	26
4.1.1	Overview	26
4.1.2	General Installation Instructions	28
4.1.3	Electrical Installation of Standalone Operation	28
4.1.4	Electrical Installation of Standalone Controller for Extended Operation	29
4.1.5	Installation of PLC Interface for Extended Controller	30
4.2	Mechanical Installation of the Pump/Motor	32
4.3	Mechanical Installation of the Controller	32
4.4	Mechanical Installation of Adapter/Extension Cables	32
5	Operation	33
5.1	System Operation with Standalone Controller	33



5.1.1	State Diagram of Standalone Controller.....	33
5.1.2	Standalone Operation (Button Control Mode)	34
5.1.3	Extended Operation (Analog Control Mode)	34
5.1.4	Error Display on the Integrated Panel	35
5.2	System Operation with Extended Controller (REV6A1).....	36
5.2.1	State Diagram of the PLC Interface	36
6	Inspection and Maintenance.....	38
6.1	Impeller Replacement Interval	38
6.2	Impeller Replacement Procedure.....	38
6.2.1	Preparation	38
6.2.2	Instructions for Replacement	39
7	Troubleshooting.....	41
7.1	Troubleshooting for Operation with Standalone Controller	41
7.2	Troubleshooting for Operation with Extended Controller	41
7.3	Troubleshooting with Service Software	41
8	Technical Support	42
9	Appendix	43
9.1	Regulatory Status	43
9.1.1	CE Marking.....	43
9.2	Symbols and Signal Words	44

1 SAFETY PRECAUTIONS

<div>CAUTION</div> <p><i>Do not open the motor or controller. Trebor does not assume responsibility for any damage occurring under such circumstances.</i></p>		
	<div>CAUTION</div> <p>High magnetic field strength of pump impeller <i>The pump system contains a rotor magnet with high field strength. This may alter or damage the calibration of sensitive electronic devices and measuring instruments in the immediate surroundings. Keep at a safe distance from computers, monitors and all magnetic data storage media (e.g. disks, credit cards, audio and video tapes etc.)</i></p>	
	<div>⚠ WARNING</div> <p>Hazardous voltage may be present. <i>In case of the usage of an inadequate AC/DC power supply, mains voltages may be present (even if the system is designed for 48VDC). The usage of a galvanic separated power supply, which is certified by a 3rd party (UL or CE), is highly recommended.</i> <i>The controller must be grounded and placed in a spill protected environment. Do not under any circumstances open the powered controller. The usage of galvanic separated AC/DC supply is highly recommended.</i></p>	
	<div>⚠ WARNING</div> <p>High magnetic field strength of pump impeller <i>The pump system contains a rotor magnet with high field strength. Pacemakers may be influenced and magnetic forces may lead to contusions. Keep distance to pace makers and handle impeller with care.</i></p>	
	<div>⚠ WARNING</div> <p>TOXIC CHEMICALS may be present. <i>When using the system to pump chemicals skin contact and toxic gases may be hazardous to your health. Wear safety gloves and other appropriate safety equipment.</i></p>	

2 SPECIFICATIONS

2.1 Specification of Components

Figure 1 shows the main system components. The accessories are listed below.




Figure 1 – Standard Components (Cables not shown)

Each Rev6 pump system is comprised of a pump, a motor, a controller, and two fluid port adapters. Table 1 lists each part:

Table 1 – Major Component Part List

Component	Item	PN	Description	Materials of Construction
Pump	1	BM001	Pump Casing	PTFE
	1a	BM001-01	Pump Casing (Integrated 1" Flare)	PTFE (Not Shown in Diagram)
	2	98004267	Pump Impeller	PFA flow path
	3	98004268	Pump Main Seal	Semiconductor grade FFKM
	4	BM002	Inlet Housing	PTFE TFM 1600
	4a	BM002-01	Inlet Housing (Integrated 1" Flare)	PTFE (Not Shown in Diagram)



Component	Item	PN	Description	Materials of Construction
	5	BM003	Union Nut	Polypropylene
Fluid Port Adapter	6	-	Seal	See Table 3 for details
	7	-	Fluid Port Adapter	
Motor Mounting Screws	8	98004269	M6x25mm QTY 4	316 stainless steel
Controller	9a	98004271	Standalone Controller	Standalone Controller 48VDC/600W Power Panel control for motor speed Optional PLC control
	9b	98004275	Extended Controller	Extended Controller 48VDC/600W Power PLC control
Motor	10	98004270	600W Motor	Standard 3 meter cables included (not shown) FEP Jacket IP67 rated liquid and dust protected

The Rev6 can be ordered as an individual pump to replace a current installation. In order to have a fully functioning unit (i.e., for a new installation) a motor, controller, connecting cables, power supply and fluid port adapters are required. The pump will not operate without a motor and controller.

Table 2 – Standard System Configurations

Product	Description	Included	Additional Required Items
REV6A0	Pump with PP union nut and 316 SS bolts (Standalone Control)	<ul style="list-style-type: none"> - Pump - Attachment Screws - Pump Manual - Pump motor - Standalone pump controller 	<ul style="list-style-type: none"> - Power cable - Sensor cable - Power supply - Fluid port adapters
REV6A1	Pump with PP union nut and 316 SS bolts (Extended Control)	<ul style="list-style-type: none"> - Pump - Attachment Screws - Pump Manual - Pump motor - Extended pump controller 	<ul style="list-style-type: none"> - Power cable - Sensor cable - Power supply - Fluid port adapters
REV6A2	Pump with PP union nut, 316 SS bolts, and integrated 1" Flare fluid ports (Standalone Control)	<ul style="list-style-type: none"> - Pump - Attachment Screws - Pump Manual - Pump motor - Standalone pump controller 	<ul style="list-style-type: none"> - Power cable - Sensor cable - Power supply



Product	Description	Included	Additional Required Items
REV6A3	Pump with PP union nut, 316 SS bolts, and integrated 1" Flare fluid ports (Extended Control)	<ul style="list-style-type: none"> - Pump - Attachment Screws - Pump Manual - Pump motor - Extended pump controller 	<ul style="list-style-type: none"> - Power cable - Sensor cable - Power supply

Wide varieties of industry standard fluid interfaces are available in the fluid port adapter. The fluid port adapter assures seamless fit between plant infrastructure and the Rev6 pump. All fluid port adapters are manufactured out of ultrapure PFA for the highest chemical compatibility and purity and can be used interchangeable between any Rev6 pump.

Two seal types are available on the pump side. The first is a PTFE gasket seal to ensure chemical compatibility. The second is a semiconductor grade FFKM o-ring seal. The seal is specifically designed to maintain sealing characteristics even at elevated temperatures. The types of adapters currently available are shown below.

Seal-less options are available as well. These configurations utilize an integrated 1" Flare fitting on the inlet and outlet, therefore a seal is not needed.

Table 3 – Fluid Port Adapters

Seal Type	PN	Part Description	Plant Connection
PTFE Gasket	G12000-10	GROUP;ADPTR;3/4IN PIPE;PTFE GSKT	3/4" weldable pipe
	G12F08-10	GROUP;ADPTR;1/2 IN FLR;PTFE GSKT	1/2" flare
	G12F12-10	GROUP;ADPTR;3/4FLR;PTFE GSKT;PVDF NUT	3/4" flare
	G12F16-10	GROUP;ADPTR;1IN FLR;PTFE GSKT	1" flare
	G12P12-10	GROUP;ADPTR;3/4 FNPT;PTFE GSKT	3/4" female NPT
	G12PL12-10	GROUP;ADPTR;3/4 PRIMELOCK;PTFE GSKT	3/4" PrimeLock
	G12T12-10	GROUP;ADPTR;3/4T;PTFE GSKT	3/4" tube stub
	G12X12-10	GROUP;ADPTR;3/4 PILLAR;PTFE GSKT	3/4" Pillar
FFKM O-ring	O12000	GROUP; ADPTR; 3/4 IN PIPE; FFKM O-RING	3/4" weldable pipe
	O12F08	GROUP;ADPTR;1/2IN FLARE;FFKM O-RING	1/2" flare
	O12F12	GROUP;ADPTR;3/4IN FLARE;FFKM O-RING	3/4" flare
	O12F16	GROUP;ADPTR;1IN FLARE;FFKM O-RING	1" flare
	O12P12	GROUP;ADPTR;3/4IN FNPT;FFKM O-RING	3/4" female NPT
	O12PL12	GROUP;ADPTR;3/4IN PRMLCK;FFKM O-RING	3/4" PrimeLock
	O12T12	GROUP;ADPTR;3/4IN TUBE;FFKM O-RING	3/4" tube stub
	O12X12	GROUP;ADPTR;3/4IN PILLAR;FFKM O-RING	3/4" Pillar Super 300
Seal-less	REV6A2	PUMP;REV6;1.0FLR;INTEGRATED;CONTROLLER	1" flare
	REV6A3	PUMP;REV6;1.0FLR;INTEGRATED;CONTROLLER;EXTENDED	1" flare

If additional fluid connections are needed, contact your Trebor representative for options
All flare nuts are constructed of PVDF. PFA nuts are available on request.
PrimeLock and Pillar Super 300 are trademarks of Entegris, Inc. and Nippon Pillar Packing Co. LTD, respectively.

Additional components are available for the Rev6. Extension cables to pair the controller to the pump are available at several different lengths. A sensor cable and power cable are needed for each motor/controller pair. A 48V power supply is also needed for the motor and controller. The specific

accessories and part numbers are listed below. See 2.2 below for descriptions and diagrams of different pump setups.

Table 4 – Additional Accessories

Accessory	PN	Description	Comments
Power Cable	98004272-01	CABLE;POWER;0.5m;REV6	PVC Jacket Circular AMP and D-Sub Plastic Connectors
	98004272-02	CABLE;POWER;3m;REV6	
	98004272-03	CABLE;POWER;5m;REV6	
	98004272-04	CABLE;POWER;7m;REV6	
	98004272-05	CABLE;POWER;10m;REV6	
Sensor Cable	98004273-01	CABLE;SENSORS;0.5m;REV6	PVC Jacket Circular AMP and D-Sub Plastic Connectors
	98004273-02	CABLE;SENSORS;3m;REV6	
	98004273-03	CABLE;SENSORS;5m;REV6	
	98004273-04	CABLE;SENSORS;7m;REV6	
	98004273-05	CABLE;SENSORS;10m;REV6	
Power Supply	98004274	POWER SUPPLY;48V;REV6	TSP-600-148-M (M=Modified design from Traco) Output: 48 VDC, 600 W Input: 85-265 VAC (auto detect) CE, CB, UL, CSA, SEMI F47
Air Cooling Module	98004282	MODULE;AIR COOLING;REV6	PP (+40% Talc) NPT 1/4" Connection 1-3 bar (14-43 psi) – 100 LPM @ 1 bar

2.2 Standard System Configurations

2.2.1 Pump Only Configuration

The Rev6 pump can be purchased without a motor or controller to replace a pump in an existing installation. The Rev6 is a drop-in replacement for the Levitronix BPS-600. This configuration comes with the assembled pump and four 316 stainless steel screws to attach the pump to the motor.

2.2.2 Stand-Alone System Configuration

The stand-alone pump system configuration (Figure 2) consists of a controller with an integrated user panel to set the speed manually. The speed is adjusted using the buttons on the control panel and automatically stored in the internal EEPROM of the controller. As an alternative, the pump speed can also be set with an external analog signal.




Figure 2 – Standard System Configuration for Standalone Control (Rev6A0 or Rev6A2)

All components listed in orange boxes in Figure 2 are required for an operable system. The adapter cables (sensors and power), fluid port adapters, and power supply are sold as separate line items.

2.2.3 Extended System Configuration

The extended version of the pump system (*Figure 3*) consists of a controller with an extended PLC interface. This allows setting the speed by an external signal and enables precise closed-loop flow or pressure control in connection with either a flow or a pressure sensor. A USB interface allows communication with a PC in connection with the *Trebor Service Software*. Hence parameterization, firmware updates and failure analysis are possible.




Figure 3 – Extended System Configuration for Extended Control (Rev6A1 or Rev6A3)

All components listed in orange boxes in Figure 3 are required for an operable system. The adapter cables (sensors and power), fluid port adapters, and power supply are sold as separate line items.

2.3 General Environmental Conditions

Table 5 – Environmental Conditions for Pump System

Controller usage	Indoor
Motor with pump usage	Indoor/Outdoor
Altitude	Up to 2000 m
Operating ambient temperature	0 to 40°C
Storage ambient temperature (Extremes for transportation)	-20 to 80°C
Operating humidity range	15 to 95% relative humidity (non-condensing)
Storage humidity range (Extremes for transportation)	15 to 95% relative humidity (non-condensing)
Normal storage conditions	Ambient temp.: 20 to 30 °C Relative humidity: 50% (non-condensing)
Acceptable DC supply fluctuations	±5% of nominal voltage
Transient over-voltages typically present on the mains supply	Surge immunity according to EN 61000-4-5 (tested together with certified AC/DC power supply)
Pollution degree	2

2.4 Pump Performance Curves

2.4.1 Pressure-Flow Curves




Figure 4 – Rev6 Flow vs Diff Pressure Curves

2.4.2 NPSHr Curves




Figure 5 – NPSHr Curves

2.4.3 Maximum Static Pressure vs. Fluid Temperature




Figure 6 – Maximum Static Pressure Allowed vs. Fluid Temperature

2.5 Basic Dimensions of Main Components

All dimensions are given in mm and inches with the inch measurement in brackets.




Figure 7 – Basic Pump Dimensions




Figure 7a – Basic Pump Dimensions (Rev6A2 & Rev6A3)




Figure 8 – Alternative Mounting Position




Figure 9 – Cable and Connector Specifications




Figure 10 – Controller Basic Dimensions

2.6 Air Cooling Module

The motor can be cooled by using the air-cooling module. This module attaches to the back of the pump motor with four bolts. Section 3.4.1 gives more information on motor cooling requirements. Figure 11 shows the dimensions of the motor with the attached air-cooling module.




Figure 11 – Motor dimensions with attached air-cooling module.

2.7 Cable Minimum Bend Radius

Cable Jacket	Sensor Cable OD	Power Cable OD	Minimum Bending Radius Permanent Installation	Minimum Bending Radius Occasional Cable Movement
FEP	6.6mm	8.4mm	7x Cable OD	15x Cable OD
PVC	7.2mm	10.0mm	6x Cable OD	12x Cable OD

3 ENGINEERING INFORMATION

3.1 Sealing and Material Concept




Figure 12 – Sealing and Material Concept

Table 6 – Materials Used in the Pump and Motor

System Component	Item		Materials
	No	Description	
Pump	1	Pump Casing	PTFE
	2	Inlet Housing	PTFE
	3	Union Nut	Polypropylene
	4	Static Sealing O-ring of Pump Casing	FFKM
	5	Impeller	PFA
	6	Rotor Magnet	NdFe (rare-earth material)
	7	4 screws for pump-motor housing	316 stainless steel

System Component	Item		Materials
	No	Description	
Motor	8	Flat gasket for motor housing	FKM (FPM)
	9	Cable strain relief bushing	PVDF, cable jacket is PVC
	10	Motor housing	ETFE coating, waterproof (IP-67) Coils and electromagnetic circuit potted with an epoxy compound (UL94 V0).

3.2 Power Consumption




Figure 13 – Electrical Power Consumption

3.3 Temperature Monitoring

To avoid overheating of the system, the controller and motor temperatures are monitored. If the controller temperature exceeds 70°C (158°F) or the motor temperature 90°C (194°F) for longer than 10 minutes, the system goes into an error state and the pump stops. At 80°C (176°F) controller temperature or 100°C (212°F) motor temperature, the system immediately stops.




Figure 14 – Controller Temperature Monitoring




Figure 15 – Motor Temperature Monitoring

3.4 Thermal Management

3.4.1 Motor Temperature

The motor temperature depends on the ambient and liquid temperature, as well as on the hydraulic operation point. Figure 16 and Figure 17 illustrate the temperature characteristics of the motor depending on these parameters. For higher fluid temperatures and hydraulic operating points, active cooling is recommended. The air-cooling module is available from Trebor for this purpose.




Figure 16 - Temperature Curves of the Motor for 25°C Fluid Temperature
(Temperature is measured inside of the motor, contact temperature of surface is below this temperature)




Figure 17 - Temperature curves of the Motor for 70°C Fluid Temperature
(Temperature is measured inside of the motor, contact temperature is below this temperature)




Figure 18 – Temperature Curves of Motor with Air Cooling Module (98004282)




Figure 19 – Fluid Temperature Influence on Motor Temperature
(Measurement at 7000 RPM, 23 LPM but gradients are representative for other operational points)

The above curves are measurements of the motor temperature at certain liquid and ambient temperatures. Equation 1 shows how to calculate the motor temperature for other liquid and ambient temperatures based on these curves.

$$T_M(T_F, T_A) \approx \underbrace{T_M(T_F = 25^\circ\text{C}, T_A = 25^\circ\text{C})}_{\text{see Figure 15}} + (T_F - 25^\circ\text{C}) \cdot \underbrace{tg_{LM}}_{\text{see Figure 18}} \cdot (T_A - 25^\circ\text{C})$$

$$\begin{array}{ll} T_M = \text{Motor Temperature} & T_F = \text{Fluid Temperature} \\ T_A = \text{Ambient Temperature} & tg_{LM} = \text{Temperature Gradient Liquid/Motor} \end{array}$$

Equation 1

In order to account for thermal variations (like ambient temperature, closed chemical cabinets or corners without ventilations) and to not significantly reduce the MTBF of the motor it is recommended to keep about 20°C safety margin to the absolute thermal limit of the motor (90°C) when designing the thermal concept of the pump system.

3.4.2 Controller Temperature

Depending on the ambient temperature and the placement of the controller, additional cooling may be required (see Figure 20). To improve cooling of the controller, place the device into a moving air stream. If the controller is mounted in a compact area or adjacent to additional heat sources (e.g. a 2nd controller), ensure that there is sufficient ventilation.




Figure 20 - Temperature Curves of Controller vs. Flow and Speed

The above curves are measurements of the controller temperature at 25°C ambient. Equation 2 shows how to calculate the controller temperature for other ambient temperatures based on this curve.

$$T_C(T_A) \approx \underbrace{T_C(T_A = 25^\circ\text{C})}_{\text{See Figure 19}} + (T_A - 25^\circ\text{C})$$

$$\begin{array}{ll} T_C = \text{Controller temperature} \\ T_A = \text{Ambient Temperature} \end{array}$$

Equation 2

3.5 Hydraulic Circuit Design

Follow these general design rules for the hydraulic circuit will yield more robust pump operation and optimum priming:

1. The general rule for optimum priming behavior is to minimize the pressure drop in the inlet circuit and avoid negative pressure at the inlet of the pump.
2. Minimize tubing length and maximize the tubing ID at the inlet of the pump. This reduces the pressure drop and the tendency of cavitation.
3. Avoid any restrictions, valves, elbows, bended tubing and sharp edges at the inlet circuit of the pump, which could potentially cause cavitation resulting in gas bubble collection in the pump and potential priming loss.
4. Place the pump at the lowest point of the hydraulic circuit. Optimum is as much as possible below a tank or reservoir. This optimizes priming behavior and removal of gas bubbles.
5. Keep the liquid level in the reservoir as high as possible, which increases the inlet pressure of the pump and minimizes fluid heating.
6. In general, the pump system placement and circuit shall be designed such that gas bubbles can leave the pump housing so the pump remains primed.
7. To minimize fluid heating, the overall pressure drop in the hydraulic circuit should be reduced as much as possible.
8. Deadhead operation (pump operation when the discharge valve is closed) should be avoided. It can cause heat-up of the liquid.
9. Optimization of the fluid circuit becomes more important as the fluid temperature increases due to the higher cavitation tendency of the liquid.

Contact Trebor (see Section 8) for additional considerations and support on the hydraulic circuit design.

4 INSTALLATION

4.1 Electrical Installation of Controller

4.1.1 Overview

The Rev6 standalone controllers have signal processor controlled power converters with four switched inverters for the drive and the bearing windings of the motor. The signal processor allows precise control of pump speed and impeller position. Figure 21 shows the interfaces of the standalone controller with standalone and minimal PLC functions.



Figure 21 – Overview of the Standalone Controller Interface

Table 7 – Interface Description of Standalone Controller

Item	Interface	Description	
1	"SENSORIC"	Position, field and temperature sensor signals from motor Torque spec. for tightening of connector screws: Min. = 0.4Nm, Max. = 0.6 Nm	
2	"USER INTERFACE"	1 Digital Input	Galvanic isolation with optocoupler Lowest input voltage for high level detection: min. 5 V; typical 24 V / 16 mA; maximum 30 V / 20 mA Highest input voltage for low-level detection: max. 0.8 V Minimum input resistance: RIN = 2.2 kΩ
		1 Digital Output	Galvanic isolation with relay Relay: 1A / 30VDC, 0.3A / 125 VAC
		1 Analog Input	Analog current input: 4 – 20 mA 450 Ω shunt input
3	"POWER OUTPUT"	Drive and bearing currents of the motor Torque spec. for tightening of connector screws on motor side: Min. = 0.5 Nm, Max. = 0.6 Nm	
4	"POWER INPUT"	DC power input Torque spec. for tightening of connector screws on motor side: Min. = 0.5 Nm, Max. = 0.6 Nm	

Item	Interface	Description
5	"Power on" Green LED	LED is on if supply voltage of signal electronics is present.
6	"Power Output not active" Red LED	Red LED is off if the switched output stage of the controller is enabled. If the LED is on, the bearing and drive coils of the motor carry no current.
7	"RESET" Button	Reset button of the controller stage. The button is recessed and can be activated using a small pointed object.
8	2-Digit Display "Speed"	Rotational speed display in 100 RPM
9	"UP" Button	Button for speed increasing
10	"DOWN" Button	Button for speed decreasing
11	"Firmware" Label	Firmware version and revision number






Figure 22 – Overview of the Standalone Controller Interface


Table 8 – Interface Description of Extended Controller

Item	Interface	Description
1	"SENSORIC"	Position, field and temperature sensor signals from motor Torque spec. for tightening of connector screws: Min. = 0.4, Max. = 0.6 Nm
2	"USER INTERFACE"	2 Analog Input - Analog current input: 4 – 20 mA - 450 Ohm shunt input
		2 Analog Input - Analog voltage input 0 – 10 V - Direct connection, no galvanic isolation - 7.8 k Ω input resistance
		2 Analog Output - Analog voltage output: 0 – 5 V - Direct connection, no galvanic isolation - Max. Output current: 2mA
		4 Digital Input - Galvanic isolation with optocoupler - Lowest input voltage for high level detection: min. 5 V Typical 24 V / 16 mA, maximal 30 V / 20 mA - Highest input voltage for low level detection: max. 0.8 V - Minimum input resistance: RIN = 2.2 k Ω
		4 Digital Output - Galvanic isolation with relay - Relay: 1A / 30VDC, 0.3A / 125 VAC
3	"USB"	USB interface
4	"POWER OUTPUT"	Drive and bearing currents of the motor. Torque spec. for tightening of connector screws on motor side: Min. = 0.5 Nm, Max. = 0.6 Nm

Item	Interface	Description
5	"POWER INPUT"	DC power input Torque spec. for tightening of connector screws on motor side: Min. = 0.5 Nm, Max. = 0.6 Nm
6	"Power on" Green LED	LED is on if supply voltage of signal electronics is present.
7	"Power Output not active" Red LED	LED is off if the switched output stage of the controller is enabled. If the LED is on, the bearing and drive coils of the motor carry no current.
8	"RESET" Button	Reset button of the controller stage

4.1.2 General Installation Instructions

	⚠ WARNING	
	<p>Hazardous voltage may be present.</p> <p><i>Always isolate the electrical power supply before making or changing connections to the unit.</i></p> <p><i>In case of the usage of an inadequate AC/DC power supply, mains voltages may be present (even if the system is designed for 48VDC). The usage of a galvanic separated power supply, which is certified by a 3rd party (UL or CE), is highly recommended.</i></p>	

	⚠ WARNING
	<p>Hazardous voltage may be present.</p> <p><i>The controller housing must be properly grounded and placed in a spill protected environment. Use one of the DIN-rail screws on the back side of the controller housing.</i></p> <p><i>Do not use different and longer screws, which may result in short-circuits within the controller.</i></p>

1. The controller casing must be grounded. The screws of the DIN-rail bracket can be used for grounding.
2. Connect the two motor connectors ("POWER OUTPUT" and "SENSORIC") to the controller.
3. Connect the controller type specific connectors: see Section 4.1.3 for standalone operation with the Standalone Controller and Section 4.1.4 for Extended operation with the Extended Controller.
4. The pump system requires 48 VDC supply voltage at a maximum power of 600 W. Depending on the desired hydraulic operational point, smaller power supplies may be used. Also, a larger supply may be used to power several pump systems simultaneously. Figure 13 shows the power consumption depending on the pressure and flow rate. Contact Trebor for additional information on a power supply solution.
5. Connect the DC power supply connector with the cable (included with the controller). Make sure that the polarity is correct (see Figure 21) and that AC/DC power supply is off.
6. To secure the connectors, tighten all retaining screws according to the torque specifications in Table 7 for the standalone controller and Table 8 for extended controller.

4.1.3 Electrical Installation of Standalone Operation

For standalone operation, the controller is disabled when power is turned on. It can be enabled manually by pressing the "UP" button on the display. If the controller will be enabled automatically when power is applied, the "ENABLE" pin on the "USER INTERFACE" connector (see Table 9) has to be active (typically 24V).

4.1.4 Electrical Installation of Standalone Controller for Extended Operation

If the *REV6A0* shall be controlled with external signals the “USER INTERFACE” can be used with the PIN designations described in Table 9.

Table 9 – Description of “USER INTERFACE” Connector

Pin	Pin Number	Function	Name	Levels	Note
Signal	5	Analog In	Reference Speed	4-20 mA = 0-10000 rpm	Direct connection, no protection. Galvanic isolation on the user side is required.
Ground	6			Upper Speed Limit = 9000 rpm ≈ 18.4 mA	
Signal	3	Digital In	Enable	Lower Speed Limit = 300 rpm	Needed to enable the system with an external signal.
Ground	4			24 V → active 0 V → not active	
Signal	1	Digital Out	Status	Relay closed → active, system on	This signal indicates if the system is active.
Ground	2			Relay open → not active, system off	




Figure 23 – “USER INTERFACE” Connector

- Delivered with Controller
- Connector Type: AK1550/06-3.81-Green



Figure 24 – “USER INTERFACE” Pin Numbering

4.1.5 Installation of PLC Interface for Extended Controller

To operate the pump system with a PLC, a minimum set of two digital inputs and one analog input is needed. The digital and analog outputs can be used to monitor the pump status and operating parameters.

CAUTION

The analog inputs and outputs are not galvanic isolated from the controller electronics. To avoid ground loops and malfunctions, use floating analog signals.

1. Detach the PLC connector from the controller
2. Connect the designated wires of a cable the pins of the detached connector according to Table 10. Assignment and functions of the I/Os can be changed with the controller firmware version (refer to according firmware documentation).
3. Connect the PLC connector (Figure 25) to the controller.




Figure 25 - PLC Connector
 - Delivered with controller
 - Supplier: Weidmüller
 - Connector Type: B2L 3.5/28 SN BK BX




Figure 26 – Mounted PLC connector and Pin Numbering

Pin Name	Connect Pin #	Designation	Levels	Note
Analog In1, (Signal)	18	Actual Process Control Value (Current Input)	4..20 mA = 0..100%	<div>- Grounds are internally connected</div> <div>- Direct connection, no protection. Galvanic isolation on the user side is required.</div> <div>- Default input settings: Current inputs selected. Voltage input can be selected with EEPROM–editor in Service Software (consult detailed firmware specification Service Software Manual).</div>
Ground Analog In1	17			
Analog In2, (Signal)	20	Ref Value (Current Input)	4..20 mA = 0..10000 rpm (speed mode) -> Speed Limit = 9000 rpm -> Cut-off (min.) speed = 300 rpm	
Ground Analog In2	19		4..20 mA = 0..100% (process mode)	
Analog In3, (Signal)	22	Actual Process Control Value (Voltage Input)	0..10 V = 0..100 %	
Ground Analog In3	21			
Analog In4, (Signal)	24	Ref Value (Voltage Input)	0..10 V = 0..10000 rpm -> Speed Limit = 9000 rpm -> Cut-off (min.) speed = 300 rpm 0..10 V mA = 0..100% (process mode)	
Ground Analog In4	23			
Analog Out1, (Signal)	26	Actual Process Control Value	0..5 V = 0..100%	Direct connection, no protection. Galvanic isolation on the user side is required. 5V is given by firmware, hardware allows up to 10V output voltage.
Analog Out2, (Signal)	28	Actual Speed	0..5 V = 0..10000 rpm	
Com. Ground Analog Out	25, 27	--	--	
Digital In1, (Signal)	2	Process mode	24 V => active 0 V => not active	Switches between process mode and speed mode
Ground Digital In1	1			
Digital In2, (Signal)	4	Enable	24 V => active, system on 0 V => not active, system off	The Enable signal switches the pump system on and off.
Ground Digital In2	3			
Digital In3, (Signal)	6	Reset	24 V => active 0 V => not active	Resets error state
Ground Digital In3	5			
Digital In4, (Signal)	8	Not used	--	--
Ground Digital In4	7			
Digital Out1	10	Warning	Relay closed => not active, system o.k. Relay open => active, system not o.k.	The warning signal indicates if a system fault has been detected. The warning signal indicates a system fault but the system does not shut down
Ground Digital Out1	9			
Digital Out2	12	Status	Relay closed => active, system on Relay open => not active, system off	This signal indicates the state of the pump system.
Ground Digital Out2	11			
Digital Out3	14	Error	Relay closed => not active, system on Relay open => active, system off	When active, the system drives the impeller to zero rpm and shuts down. With a reset pulse the system can be re-initialized.
Ground Digital Out3	13			
Digital Out4	16	Not Used	-	-
Ground Digital Out4	15			


Table 10 - Signals of the PLC connector for standard firmware D8.48

- For other configurations of PLC Inputs and Outputs refer to alternate firmware documentation
 - Configurations can be done with Trebor Service Software

4.2 Mechanical Installation of the Pump/Motor

- The motor can be fixed with four screws on the motor feet (see Figure 7)
- As an alternative the motor can be mounted with four screws on the back (see Figure 8)
- The motor can be mounted in either the horizontal or the vertical position
- Each motor is identified with a unique serial number. This serial number consists of a series of 6 digits where the 5th and the 6th digit represent the manufacturing year.

4.3 Mechanical Installation of the Controller

	⚠ WARNING
	<p>Hazardous voltage may be present.</p> <p><i>In order to avoiding fluid spills shorting mains or other voltages within the controller, place the controller in a spill-protected environment (for example protected electronic cabinets).</i></p> <p><i>If explosive flammable gases are present, place the controller in an explosion-proof cabinet.</i></p>

CAUTION
<p><i>Make sure the controller is mounted in a position that allows free air circulation around the controller. A minimum distance of 10cm (4") to other objects above or below the controller casing is recommended.</i></p>

- Use the Din-Rail bracket to mount the controller.
- If no forced air-cooling is used, mount the controller in upright position.
- The Din-Rail brackets can also be mounted on the controller side according to Figure 10

CAUTION
<p><i>Use only 3.5 x 6.5mm self-tapping screw for the fixation of the Din-Rail brackets. The controller may be damaged if other screws are used!</i></p>

4.4 Mechanical Installation of Adapter/Extension Cables

For connecting the motor to the controller, use adaptor cables 98004272-## (for power cable) and 98004273-## (for sensor cable) (see Table 4 for details).

5 OPERATION

5.1 System Operation with Standalone Controller

5.1.1 State Diagram of Standalone Controller

The standalone controller allows operation with manual speed setting (Button Control Mode) as well as extended operation with analog speed setting (Analog Control Mode). Figure 27 shows the state diagram, which can be controlled with the manual buttons and the signals on the “USER INTERFACE” connector. The operation mode can be chosen by pressing the “UP” and “DOWN” buttons simultaneously for five seconds. The default setting from the factory is “Button Control Mode”.




Figure 27 - State Diagram for Standalone Controller Operation

(Description is for firmware D6.25 with Revision > 01, for other configurations refer to alternate firmware documentation)

5.1.2 Standalone Operation (Button Control Mode)

- When applying power the system defaults into the “*Button Control Mode*” and goes into the status “*OFF Button Control*” according to Figure 27. Levitation is disabled and the display indicates “*OF*”.
- Levitation can be enabled by pressing the “*UP*” button for 1 second (display shortly indicates “*ON*”) or by activating (typically 24V) the “*ENABLE*” pin on the “*USER INTERFACE*” connector (see Table 9). The system goes then into the status “*ON Button Control*” and is running at the speed, which is stored in the EEPROM.
- The speed can be changed by pressing accordingly the “*UP*” and “*DOWN*” buttons. As long as the digits on the display are blinking, the “set speed” is shown. As soon as blinking stops the actual speed is shown and the “set speed” is stored in the EEPROM of the controller.
- The system can be disabled by pressing the “*DOWN*” button until 0 rpm is achieved. Pressing further 1 second the “*DOWN*” button the system disables levitation and shows “*OF*” on the display. The system can also be disabled by deactivating (0 V) the “*ENABLE*” pin on the “*USER INTERFACE*” connector (see Table 7). Before disabling the system, the speed is automatically reduced to 0 rpm and the impeller is properly touched down without grinding the wall.
- In case of an error the “*RESET*” button (see Figure 21) can be used to restart the system or the power can be switched off and on.
- For error analysis, the codes described in Table 11 are displayed (blinking between “*Er*” and the according code number).
- If the system shall be enabled automatically, when power is applied the “*ENABLE*” pin on the “*USER INTERFACE*” connector (see Table 7) has to be active (typically 24V). When switching on the power the system is running with the stored speed.
- For monitoring purposes, a digital output on the “*USER INTERFACE*” connector (see Table 7) indicates the status of the system. When the impeller is rotating the digital output “*Status*” turns active.

The digital input “*ENABLE*” is normally edge-triggered to allow control by digital input and buttons in order to enable/disable systems simultaneously. An exception is, when the system is powered up or a system reset occurs: then the system checks the level of the digital input and switches to the desired state. Hence, on startup, a high level of the digital input “*ENABLE*” is sufficient to switch on the system and a transition from low to high is not required.

5.1.3 Extended Operation (Analog Control Mode)

- In order to be able to control the pump with external signals, the mode “*Analog Control Mode*” has to be set with the display buttons. Press the “*UP*” and “*DOWN*” buttons simultaneously for 5 seconds. The display should show the mode change by blinking between the stored speed value and “*An*”. The chosen mode is then stored in the EEPROM of the controller. After startup, the system returns to the operation mode selected previously.
- The system and levitation can be enabled/disabled with the digital input on the “*USER INTERFACE*” connector (see Table 9). When disabling the running system the speed is automatically reduced to 0 rpm and the impeller is properly touched down without grinding the wall. The display is blinking between “*An*” and “*OF*”. Alternatively “*UP*” button is also able to switch the system on. Pressing the “*DOWN*” button will switch the system off.
- The speed can be set with an analog signal on the “*USER INTERFACE*” connector according to Table 9. It is strongly recommended to use galvanic separated signal values.
- For monitoring purposes, a digital output “*Status*” on the “*USER INTERFACE*” connector (see Table 9) indicates the status of the system. When the impeller is rotating the digital output “*Status*” turns active.

5.1.4 Error Display on the Integrated Panel

Error Source	Errors	Error Code on Display
Motor	No motor	<i>Er 01</i>
Motor	Motor cable (power wires) not connected to controller	<i>Er 02</i>
Motor	Motor cable (sensor wires) not connected to controller	<i>Er 03</i>
Motor	No impeller	<i>Er 04</i>
Controller	Short circuit	<i>Er 05</i>
Controller	Over current in the bearing coils	<i>Er 06</i>
Controller	Over current in the drive coils	<i>Er 07</i>
Controller	DC-Link voltage out of range (< 40 or > 54 V DC) If the voltage is out of range the system starts to reduce the speed and a warning is generated. When reaching 0 rpm and the voltage is still out of range the system is disabled and an error is generated. In case the voltage is again within the range during speed reduction the system switches to normal operation and no Error is generated.	<i>Er 08</i>
Controller	Communication problems EEPROM Controller	<i>Er 09</i>
Motor	Communication problems EEPROM Motor	<i>Er 10</i>
Controller	Controller temp. over 80°C or more than 10 minutes above 70°C	<i>Er 11</i>
Motor	Motor temp. over 100°C or more than 10 minutes above 90°C	<i>Er 12</i>
Pump	Dry running of pump circuit: -> Pump keeps running on reduced speed (5000 rpm) -> The system accelerates to the original speed value when the pump is refilled with liquid. -> Note that the speed is only reduced during dry running if the pump speed was ≥ 6000 rpm.	<i>Blinking dots on display</i>

Table 11 - Errors and Warnings with Indication on Standalone Controller Display

- *In case of an error the system can only be restarted with a reset or a power supply restart*
- *For other configurations of error codes refer to alternate controller or firmware documentation*

5.2 System Operation with Extended Controller (REV6A1)

5.2.1 State Diagram of the PLC Interface




Figure 28 – PLC Interface State Diagram

State “Off”:

The pump system is switched off and the motor has no power. In this state, Trebor Service Software has full control.

State “ON” (speed control mode):

The pump system is switched ON and the impeller is rotating with the referenced speed. The motor has electrical power when in this state.

State “ON” (process control mode):

The pump system is switched ON and the impeller is rotating with the priming speed. The motor has electrical power when in this state.

State “Error”:

If an error according to Table 12 occurs in the pump system, the system defaults to the *Error* state. The designated digital output on the PLC Interface is activated. The pump system is switched OFF. By activating the “Reset” input the system gets back to the “Off” state.

Error Source	Errors	Effect on Designated Digital Output of the PLC
Motor	No rotor	Error = relay open
Motor	Temperature over 100°C	Error = relay open
Motor	Temperature was higher than 90°C for more than 10 minutes.	Error = relay open
Motor	Temperature more than 90°C	Warning = relay open
Motor	No motor temperature signal	Warning = relay open
Motor	Motor power cable not connected with controller	Error = relay open
Motor	Motor sensor cable not connected with controller	Error = relay open
Controller	Over-current	Error = relay open
Controller	Power channel interrupted	Error = relay open
Controller	Temperature over 80°C	Error = relay open
Controller	Temp. was higher than 70°C for more than 10 minutes.	Error = relay open
Controller	DC link (supply voltage) out of range (< 40 or > 54 V DC) If the voltage is out of range the system starts to reduce the speed and a warning is generated. When reaching 0 rpm and the voltage is still out of range the system is disabled and an error is generated. In case the voltage is again within the range during speed reduction the system switches to normal operation and no Error is generated.	Error = relay open
Controller	Temperature over 70°C	Warning = relay open
Controller	Dry Running Detection -> Pump keeps running on reduced speed (5000 rpm) -> The system accelerates to the set speed value when the pump is refilled with liquid -> Note that the speed is only reduced during dry running if the pump speed was ≥ 6000 rpm	Warning = relay open
Controller	Trend warning (actual speed too high)	Warning = relay open

Table 12 – Possible Errors and Warnings with Indication on PLC Interface

6 INSPECTION AND MAINTENANCE

6.1 Impeller Replacement Interval

The impeller has a limited lifetime depending on the type, concentration, and temperature of the fluid being pumped. Therefore, a preventive periodical exchange of the impeller is recommended. Contact the *Trebor Technical Service Department* (see Section 8) for further information on replacement times.

6.2 Impeller Replacement Procedure

6.2.1 Preparation

Before starting the impeller replacement procedure, understand the placement and function of the parts and tools shown in Figure 24 and Figure 25. The rebuild kit contains these parts and tools shown in Figure 25. Please verify that you have the right impellers, and O-rings.




Figure 29 – Labeled Exploded View of Pump




Figure 29a – Labeled Exploded View of Rev6A2 & Rev6A3 Configurations

⚠ WARNING



The impeller could splash **TOXIC** or **CORROSIVE** **CHEMICALS** because of the strong magnetic forces. Flush the pump housing before opening it.

⚠ WARNING



HARMFUL CHEMICALS may be present. Skin contact and toxic gases may be hazardous to your health. Wear safety gloves and other appropriate safety equipment.

⚠ CAUTION




The rotating impeller could cause injury. Do not run the pump system when opening the pump head.



Figure 30 – Rev6 Rebuild Kit

The following warnings and cautions should be read carefully before starting the replacement of the impeller.

⚠ CAUTION				
				
<p><i>Pay attention to the magnetic forces when handling the impeller. The attraction of magnetic parts and particles should be avoided in order to keep the impeller and the pump head clean and free of contamination.</i></p>				

6.2.2 Instructions for Replacement


1. Power down the pump system and remove the AC power. If necessary, allow the motor housing to cool down to a workable temperature.
2. Unscrew and remove the union nut. Trebor provides a tool (T0180 - Tool; Union Nut; Socket; Rev6) to loosen the union nut or a strap wrench may be used.



3. **REV6A0 or REV6A1**
Loosen the fluid port adapter enough to insert the Impeller Removal Tool. Use the tool to pull the inlet housing and main seal o-ring from the pump casing.
REV6A2 or REV6A3
Thread 1" flare nut fully onto inlet housing and utilize nut to pull inlet housing by hand.



4. Gently slide the nose of the Impeller Removal Tool into the center hole of the impeller. Squeeze the handle of the tool and pull the impeller from the pump casing.



5. Inspect the wet area of the pump head carefully. In case of material damage, replace the pump casing and inlet housing.
6. Place the new impeller into the pump casing using the Impeller Removal Tool.
7. If necessary, remove the existing O-Ring and gently press the new O-Ring into the shoulder of the inlet housing.

CAUTION

*Use the correct O-Ring type for your process. If necessary, consult your Trebor representative.
Do NOT twist or roll the O-Ring as this may cause leaking to occur.*

8. Align the tabs on the inlet housing with the slots in the pump casing. Press the inlet housing into the pump casing. Ensure the housing is fully seated in the casing. The top edge of the inlet housing should be ~2.5mm (0.1in) above the casing when fully seated.



9. Carefully tighten the union nut. Tighten by hand until the union nut is flush with the surface of the inlet housing. Add an additional 1/8 turn or 8-9 Nm (70-80 in-lbs.) of torque.
10. Start up the system and check if the impeller is rotating properly and the pump head does not leak.

11. If the pump head leaks, inspect that the housing and o-ring are properly pressed into the bottom of the pump casing. If the o-ring has been damaged, it may be necessary to replace it.
- Troubleshooting

6.3 Troubleshooting for Operation with Standalone Controller

For troubleshooting and failure analysis with the stand-alone controller the following procedure is recommended:

- Check the status of the LEDs. The specific LEDs are described in Table 7
- Use the ERROR codes on the display. The specific error codes are described in Table 11.
- A digital output on the “USER INTERFACE” connector (“Status”) indicates if the system is active. However, the source of an error cannot be identified by this signal.

6.4 Troubleshooting for Operation with Extended Controller

The integrated PLC provides a Warning and an Error signals according to Table 12. However, the source of error cannot be identified by these signals.

For more detailed analysis the *Trebor Service Software* can be used with a PC and a USB interface to the controller.

6.5 Troubleshooting with Service Software

The *Trebor Service Software* allows communication with the pump system in connection with a PC and a USB interface. The software can be used for performing detailed troubleshooting. For usage of the Service Software refer to the *Service Software User Manual*. Contact Trebor International Technical Support (see under *Section 8*).

Note: the Service Software cannot be used with the standalone controller (*REV6A0*).



7 TECHNICAL SUPPORT

For troubleshooting, support and detailed technical information contact

TREBOR

8100 South 1300 West
West Jordan, Utah 84088 USA
Tel: (801) 561 0303
Toll Free: (800) 669 1303
Fax: (801) 255 2312

8 APPENDIX

8.1 Regulatory Status

8.1.1 CE Marking



Machinery Directive 2006/42/EC (Safety)

EMC Directive 2004/108/EC Electromagnetic Compatibility

The *Rev6 pump*, in its various configurations as listed below, is in conformity with the above-mentioned European Directives.

Part Name	Description
Rev6A0	Pump casing consisting of various fittings and o-rings See F0117C
Rev6A1	Pump casing consisting of various fittings and o-rings See F0117C
Rev6A2	Pump casing consisting of integrated 1" flare fittings.
Rev6A3	Pump casing consisting of integrated 1" flare fittings.
98004270	Bearingless motor See DC-4003-03, Rev05
98004271	Standalone Controller with 48 VDC, 600 W supply inputs (galvanic separated from high voltage side) See DC-4003-03, Rev05
Accessories	Motor controller adapter cables of various lengths, air-cooling module, and others. See DC-4003-03, Rev05

Machinery Directive 2006/42/EC:

The machinery directive essentially has been followed by a risk analysis, according mitigation actions and a user manual for safe operation. For design and testing, the following standards are used as a guideline:

EN 809 Pumps and pump units for liquids: basic requirements are followed.

EN 12162 Liquid Pumps – Safety Requirements - Procedure for hydrostatic testing: used for maximum static pressure testing of pump.

ISO 12100 Safety of machinery – principles for risk assessments: used for system risk analysis.

EMC Directive 2004/108/EC:

The following standards of the EMC directive are tested and confirmed at a certified laboratory:

EN61000-6-2 Generic standards, Immunity for industrial environments

EN61000-6-4 Generic standards, Emission standard for industrial environments













Test Laboratory: Hochschule für Technik Zürich

EMV Labor, Technoparkstr. 1

CH-8005 Zurich, Switzerland

Swiss certification number = STS 404

8.2 Symbols and Signal Words

Symbol / Signal Word	Description	Type	Source
DANGER	Indication of an imminently hazardous situation that, if not avoided, will result in death or severe injury. Limited to the most extreme situation	Signal word	SEMI S1-0701
WARNING	Indication of a potentially hazardous situation, which if not avoided, could result in death or severe injury.	Signal word	SEMI S1-0701
CAUTION	Indication of potentially hazardous situations, which if not avoided, could result in moderate or minor injury. Also, alert against unsafe practice. Without safety alert indication of hazardous situation which, if not avoided, could result in property damage.	Signal word	SEMI S1-0701
	Safety alert for "Warning" and "Caution"	Safety alert	SEMI S1-0701
	Safety alert for "Danger"	Safety alert	SEMI S1-0701
	Caution (refer to accompanying documents) (is used on article labels for reference to manual)	Refer to manual	ISO 3864
	Toxic material, poison	Hazard identification	IEC 61310
	Corrosive material, corrosion	Hazard identification	IEC 61310
	Cut/sever hand, sharp object	Hazard identification	ANSI Z535.3
	Strong magnetic field	Hazard identification	SEMI S1-0701
	Danger: electricity, electrical hazard	Hazard identification	IEC 61310, ISO 3864
	Wear safety gloves	Hazard avoidance Mandatory action	IEC 61310
	Wear face shield	Hazard avoidance Mandatory action	SEMI S1-0701
	Unplug power line	Hazard avoidance Mandatory action	SEMI S1-0701
	No pacemakers	Hazard avoidance Prohibition	SEMI S1-0701